

ਦਫਤਰ ਨਗਰ ਕੌਂਸਲ ਫਾਜ਼ਿਲਕਾ (ਜਿਲ੍ਹਾ ਫਾਜ਼ਿਲਕਾ)

ਨੰ:- ੨੦/

ਮਿਤੀ:- ੨੧-੪-੨੬

ਵੱਲੋਂ, ਕਾਰਜ ਸਾਧਕ ਅਫਸਰ, ਨਗਰ ਕੌਂਸਲ ਫਾਜ਼ਿਲਕਾ ।	ਵੱਲੋਂ, Holy Heart Day Boarding Public School Fazilka.
---	--

ਵਿਸ਼ਾ:- ਸੈਨੀਟੇਸ਼ਨ ਸਰਟੀਫਿਕੇਟ ਸਬੰਧੀ ।

ਹਵਾਲਾ:- ਆਪ ਦਾ ਪੱਤਰ ਨੰ:-HADB/2026-27 Dated:- 13-04-26 ਦੇ ਸਬੰਧ ਵਿੱਚ ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਅਤੇ ਹਵਾਲੇ ਅਧੀਨ ਪੱਤਰ ਦੇ ਸਬੰਧ ਵਿੱਚ ਆਪ ਨੂੰ ਲਿਖਿਆ ਜਾਂਦਾ ਹੈ ਕਿ ਆਪ ਦੇ ਸਕੂਲ ਵੱਲੋਂ ਜੋ ਸਫਾਈ ਵਿਵਸਥਾ ਦਾ ਕੰਮ ਕੀਤਾ ਜਾ ਰਿਹਾ ਹੈ, ਉਹ ਤਸੱਲੀਬਖਸ਼ ਹੈ ।


ਕਾਰਜ ਸਾਧਕ ਅਫਸਰ,

ਨਗਰ ਕੌਂਸਲ ਫਾਜ਼ਿਲਕਾ ।


DISTRICT WATER TESTING LABORATORY, FAZILKA

Village Panchawali, Fazilka
dwtlfazilka@gmail.com

To,

Holy Heart Day Boarding Public School Fazilka
Fazilka

No.: DWTL/EZK/2627/00010 Dated : 16/04/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. HHDB/26-27 Dated: 13/04/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 15/04/2026. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Fazilka

D/A : Test Report

(Signature)
Authorized Signatory
For, District water Testing Laboratory
Fazilka

DISTRICT WATER TESTING LABORATORY, FAZILKA

Village Panchawali, Fazilka
dwtlfazilka@gmail.com



TEST REPORT


Name & Address of Customer : Holy Heart Day Boarding Public School Fazilka Fazilka		Customer Reference No.	No : HHDB/26-27 Dated : 13/04/2026
		Sample Submitted by	Anil Kumar
		Date of Sample Receipt	15/04/2026
		Analysis Starting Date	15/04/2026
		Analysis completion Date	16/04/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC140632600000112F	Sample Type :	Water
Test Report No.:	DWTL/FZK/2627/00010	Date of Issue :	16/04/2026
Registration no.:	DWTL/FZK/REG2627/00093	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Holy Heart Day Boarding Public School Fazilka(RO Treated Water) / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Fazilka	District :	Fazilka
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.79@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	115	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO ₃)	48	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO ₃)	44	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	1	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	1	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	22	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

- The results apply to the sample as received only.
- The sample will be destroyed after retention time unless otherwise specified specially.
- This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
- Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
- * Value not available or test not performed for this parameter.
- Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By


 Ms.Sushma bala
 Chemist/Analyst
 Authorized Signatory
 For, District water Testing Laboratory
 Fazilka

----- End of the Test Report -----

